

Diasen s.r.l.  
Z.I. Berbentina, 5  
60041 Sassoferrato (AN)  
ITALY

Eurofins Product Testing A/S  
Smedeskovvej 38  
8464 Galten  
Denmark

CustomerSupport@eurofins.com  
www.eurofins.com/VOC-testing

## VOC EMISSION TEST REPORT

### CDPH

26 March 2021

#### 1 Sample Information

|                  |                        |
|------------------|------------------------|
| Sample name      | Acriflex               |
| Batch no.        | OPB2021000065          |
| Production date  | 21/01/2021             |
| Product type     | Waterproofing membrane |
| Sample reception | 08/02/2021             |


#### 2 Brief Evaluation of the Results

| Regulation or protocol | Conclusion | Version of regulation or protocol              |
|------------------------|------------|------------------------------------------------|
| CDPH                   | Pass       | CDPH/EHLB/Standard Method V1.2. (January 2017) |

Full details based on the testing and direct comparison with limit values are available in the following pages  
Regarding pass/fail decision rule please see appendix



Pernille Krintel  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry